



Certificate number: 2109718

Date issued 22nd September 2021

Date expired 21st September 2026 Original/Amendment Original

Kiwa UK Regulation 4 (KUKreg4) Approval

ATS3 – Without Production Surveillance

Issued by Kiwa Watertec (UK)

Evaluation Guideline: Kiwa UK – EG004
Reference Standards: Regulators Specification
Model Designations: see Appendix

Manufacturer: TFL India Products Private Limited.

Factor: TFL Enterprises Sp. z.o.o.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied on to comply with the above Evaluation Guideline and Standards, and can be marked with the KUKreg4mark.

The intended use of this certificate is for compliance with Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales; 2009 Northern Ireland and 2014 Byelaws Scotland

This certificate has been issued in accordance with the Kiwa regulations for product certification

Signed on behalf of Kiwa Watertec

David Jay,
Business Unit Manager – Authorised Signatory
Kiwa Watertec

Kiwa Watertec

(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate issued to:
TFL Enterprises Sp. Z.o.o.
UL. Lucka 15 lok. 10
00-842 Warszawa
NIP: 5272700547 (Tax id)



UK Approval Certificate (page 2 of 2)

Appendix to Certificate 2109718

The following products are covered by this certificate -

PRODUCT DESCRIPTION Range of Y pattern strainers with bronze bodies and PTFE gasket. ATS3 – Without Production Surveillance.
MODEL(S) PLBNST20.
SIZE: DN15, DN20, DN 25, DN 32, DN40, DN50.
SCOPE: Manufacturer recommended maximum working pressure 20 Bar & maximum operating temperature 85°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 85°C. Above ground use only.
MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.
BACKFLOW PROTECTION NOTES N/A.
MARKING TFL, SIZE, FLOW, ARROW, RG5 on body.
ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements.

Extra Notes